





TRANSFORMATOR- EN OMVORMERSTATION



NOTES:

1. EXTERNAL PAINTING RAL 6005.
2. CARPENTRY EXTERNAL PAINTING RAL 6005.

WEIGHT LIST		
	5 MVA Transformer	7260kg
	24 KV Switchgear	950kg
	LV Panel	850kg
	Concrete Skid	7600kg
	Other (cabling, etc)	500kg
	TOTAL SPS	15770kg

LEGEND	
1	5 MVA Transformer
2	24 KV MV Switchgear
3	LV Panel
4	Oil retention tank
5	Concrete Skid
6	Datalogger (Costumer Scope)
7	Scada (Costumer Scope)

	Name	Revision	Date	CUSTOMER:  PLACE OF INSTALLATION: PV BEUNINGEN (NETHERLANDS)	INSTALLATION: SPS-3500	DRAWING NAME: EXTERNAL VIEWS		ORIGINAL	DRAWING NUMBER
Realised	CSM	01	06/05/2022					FORMAT	001
Revised	BAM	01	06/05/2022						002
Approved	AGG	01	06/05/2022					A-3	006
								SCALE	1/75