

POOL

~

1547x [6L1 module frame] 282x MODULES - 4 084.08 kWp SYSTEM



Notes:

- All dimensions to be confirmed on site prior to installation.
- 2. All dimensions are indicative only and in mm
- unless otherwise specified.3. Drawing based on:
- GE Imagery date: 19/04/18;

Legend:



Site boundary Perimeter fence Maintenance track Central Inverter CCTV

System description:

DC Power kWp: AC Power kVA:

No. of modules: Module type: Dimensions:

Substructure type: Tilt angle: Shading angle: Azimuth from South: Pitch distance: Row to row distance: No. of inverters: Inverter type:

Power ratio: No. of AC combiners: No. of Transformers

Fence area: Fence length: Total area: 4 084.08 3 000 9 282 TP6H72M-440-L (440W) 2008x1002x40 6 modules in landscape 15° 28° Due South 8 019 mm 2 000 mm 3 SMA Sunny Central 1000CP XT 1.36 ---3.00 ha 700 m

Proposed location:



4.98 ha

Revisions:			
Rev Date	Comments		Drawn
Client:	Ambrosiusweg Hilvarenbeek		
Location:	Hilvarenbeek, Netherlands		
	51°31'57.20"N 5°6'35.43"E		
Title:	PV Layout		
Drawn:	DETRA / MG	Checked:	RV
Scale:	1:600@A1	Date:	22/06/21
Drawing No:	NRGA1005-100	Rev:	



Gooimeer 1, 1411 DC Naarden, Netherlands Phone: +31 35 2203016 Email: hello@nrg2all.nl www.nrg2all.nl

Do not scale from this drawing. Site verify all dimensions prior to construction. Report all discrepancies to the drawing originator immediately. This drawing is to be read in conjunction with all relevant documents and drawings.

PURCHASING STATION

SECURITY FENCE MAINTENANCE TRACK CENTRAL INVERTER CCTV GATE

